

# A & L WESTERN AGRICULTURAL LABORATORIES

1311 WOODLAND AVE #1 • MODESTO, CALIFORNIA 95351 • (209) 529-4080 • FAX (209) 529-4736



REPORT NUMBER: 00-336-060

CLIENT: 9999-D

DATE RECEIVED: 12/06/00

DATE COMPLETED: 12/08/00

SUBMITTED BY:

SEND TO: A & L WESTERN AGRICULTURAL LABORATORIES  
1311 WOODLAND AVE.  
MODESTO, CA 95351-


CUSTOMER: EXAMPLE REPORT

DATE OF REPORT: 09/02/04

## WATER ANALYSIS REPORT

PAGE: 1

Sample ID	Lab Number	Sodium Na ppm	Calcium Ca ppm	Magnesium Mg ppm	Carbonate CO <sub>3</sub> ppm	Bicarbonate HCO <sub>3</sub> ppm	Chloride Cl ppm	Conductivity E.C. mmhos/cm	pH	Copper Cu ppm	Iron Fe ppm	Manganese Mn ppm	Zinc Zn ppm
DOMESTIC	61837		103	31				0.76	7.9				

Sample ID	Phosphorus P ppm	Potassium K ppm	Nitrate NO <sub>3</sub> ppm	Sulfate SO <sub>4</sub> ppm	Boron B ppm	Dissolved Solids ppm	Total Hardness ppm	Bacteriological MPN/100ml		Comments:
								Total Coliform	Fecal Coliform	
DOMESTIC			26			486	385	PRESENT	ABSENT	<p>Does not meet current water quality standards for coliform bacteria.</p> <p>This report applies only to the sample(s) tested. Samples are retained a maximum of thirty days after testing.</p> <p> Robert Butterfield A &amp; L WESTERN LABORATORIES, INC.</p>